



**SANITARY SEWER OVERFLOW
ANNUAL REPORT**

DATE: 01/30/15

FACILITY NAME: Alum Creek Water Reclamation

OHIO NPDES PERMIT NO: 4pk00003*DD

PERIOD COVERED BY REPORT: 01/01/2014 - 12/31/2014

CONTACT PERSON

NAME: Mark Chandler

TITLE: Operations Superintendent

MAILING ADDRESS:

7767 Walker Wood Blvd
Lewis Center OH. 43035

TELEPHONE: 740-549-1906

EMAIL: mchandler@co.delaware.oh.us

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE, AND COMPLETE.

Signature of Official

1-30-15

Date

Operations Superintendent

Title



Enter narrative analysis of WIB patterns by location, frequency and cause.

301 - On 06/30/2014 The DCRSD Collections crew got an call about sewage coming out of an manhole in the subdivision of Village of Bale Kenyon . A blockage was discovered in the main line by the collections department. the blockage was cleaned and the main line was cctv to assure no blockage was present.

302 - On 11/17/2014 A homeowner called saying he had sewage in the basement at Summerwood lakes subdivision. A blockage was discovered in the main line by the collections department. the blockage was cleaned and the main line was cctv to assure no blockage was present.

303 - On 06/13/2014 A homeowner called saying he had sewage in the basement at Black Hawk Creek subdivision. A blockage was discovered in the main line by the collections department. the blockage was cleaned and the main line was cctv to assure no blockage was present.