



**SANITARY SEWER OVERFLOW  
ANNUAL REPORT**

**DATE:** 01/30/15

**FACILITY NAME:** Tartan Fields Reuse Facility

**OHIO NPDES PERMIT NO:** 4MP00008\*BM

**PERIOD COVERED BY REPORT:** 01/01/2014 - 12/31/2014

**CONTACT PERSON**

**NAME:** Mark Chandler

**TITLE:** Operations Superintendent

**MAILING ADDRESS:**

7767 Walker wood Blvd  
Lewis Center Oh. 43035

**TELEPHONE:** 740-549-1906

**EMAIL:** mchandler@co.delaware.oh.us

***I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE, AND COMPLETE.***

Mark Chandler  
Signature of Official

1-30-15  
Date

Operations Superintendent  
Title









Enter narrative analysis of WIB patterns by location, frequency and cause.

301- On 01/31/2014 A call came in saying sewage was coming out of an manhole on Tartan fields Dr. The DCRSD Collection crew discovered that an air release went bad. The DCRSD Collections crew replaced the old air release with an new air release and cleaned up around the manhole.