



**SANITARY SEWER OVERFLOW
ANNUAL REPORT**

DATE: 02/04/16

FACILITY NAME: Alum Creek Water Reclamation

OHIO NPDES PERMIT NO: 4PK00003*ED

PERIOD COVERED BY REPORT: 01/01/2015 - 12/31/2015

CONTACT PERSON

NAME: Mark Chandler

TITLE: Operations Superintendent

MAILING ADDRESS:

7767 Walker Wood Blvd.
Lewis Center OH. 43035

TELEPHONE: 740-549-1906

EMAIL: mchandler@co.delaware.oh.us

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE, AND COMPLETE.

Signature of Official

2-5-16

Date

Operations Superintendent

Title

Date ^A	Identification No. ^B	Receiving Water ^C		Volume ^D
11/20/15	301	none	Various	0.000

- A. Enter date as "MM/DD/YY". Enter "Various" to summarize overflows of less than 1000 gallons from an SSO location.
- B. Enter the unique identification assigned in Table 1.
- C. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)". If an SSO does not reach a receiving water, enter "None".
- D. Enter estimate of volume in MG (millions of gallons). Enter estimate of total volume if summarizing data.

Use additional pages as needed.

SSO Annual Report Table 3: Water In Basement Occurrences Ohio NPDES Permit No.: 4PK00003*ED

Sewershed ^A	WIB Occurrences ^B	Causes ^C
302 - Summerwood lakes subdivision	3	D (Gravel)
Total Occurrences	3	

A. A sewershed is a specific geographic area, such as a city block or a subdivision, that drains to a common outlet.

B. Enter the total number of water in basement occurrences reported for the sewershed.

C. Enter all causes that apply: W = extreme weather; E = equipment failure; P = power failure; D = debris in line; R = roots; G = grease; B = other blockages; L = line deterioration; V = vandalism; O = other, provide details.

Use additional pages as needed.

Enter narrative analysis of WIB patterns by location, frequency and cause.

301 - On 11/20/2015 The DCRSD Collections crew got a call about the contractor may have hit the East Alum Creek force main. The collections crew went out and found that the contractor had bored in to the force main .The collections crew shut down the pump station and had a contractor haul sewage from the pump station and the contractor fixed the force main.

302 - On 5/4/2015 A homeowner called saying they had sewage in the basement at Summerwood Lakes subdivision. A blockage was discovered in the main line by the collections department. Which caused three homes to have sewage in the basement. The blockage was cleaned and the main line was cctv to assure no blockage was present.