



**SANITARY SEWER OVERFLOW
ANNUAL REPORT**

DATE: 03/08/18

FACILITY NAME: Alum Creek WWTP

OHIO NPDES PERMIT NO: 4PK00003*FD

PERIOD COVERED BY REPORT: 1/1/17 -12/31/17

CONTACT PERSON

NAME: Mark Chandler

TITLE: Operations Superintendent

MAILING ADDRESS:

7767 Walker Wood Blvd.
Lewis Center, Ohio 43035

TELEPHONE: 740-833-2226

EMAIL: mchandler@co.delaware.oh.us

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION IN THIS REPORT AND ALL ATTACHMENTS. BASED ON MY INQUIRY OF THOSE PERSONS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION CONTAINED IN THE REPORT, I BELIEVE THAT THE INFORMATION IS TRUE, ACCURATE, AND COMPLETE.

Signature of Official

3-13-18

Date

Title

Identification No. ^A	Location Description	Receiving Water ^B	Eliminated ^C
301	Africa Rd. just south of Harbo Point DR.	N/A None	12/08/17

A. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.

B. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)". If an SSO does not reach a receiving water, enter "None".

C. If an SSO has been eliminated, enter the date of elimination (MM/DD/YY).

Use additional pages as needed.

Date ^A	Identification No. ^B	Receiving Water ^C	Volume ^D
12/8/17	301	N/A None	0.001

A. Enter date as "MM/DD/YY". Enter "Various" to summarize overflows of less than 1000 gallons from an SSO location.

B. Enter the unique identification assigned in Table 1.

C. Enter name of receiving water. If an SSO enters a storm sewer, enter "SS to (name of receiving water)". If an SSO does not reach a receiving water, enter "None".

D. Enter estimate of volume in MG (millions of gallons). Enter estimate of total volume if summarizing data.

Use additional pages as needed.

Enter narrative analysis of WIB patterns by location, frequency and cause.

Water in Basement on East Powell Rd. The Delaware County Collections Crew found a blockage to be between manhole 144 and 145 on Hickory Ridge Court. We jetted the main line to break the blockage free .when we camera the main line we saw some white pvc pipe that was broken and in the main with some debris in the main line.



Division of Surface Water
 Non-compliance Notification for
 Bypasses and Upsets

Use this form to report non-compliance that is the result of any **unanticipated bypass** or **upset** resulting in an exceedance of any **effluent limit** in your NPDES permit (see Part III, Section 12 of your NPDES permit for details). The form should be completed and emailed to the appropriate Ohio EPA inspector, or Ohio EPA office using one of the following addresses:

Southeast District Office: sedo24hournpdes@epa.state.oh.us
 Southwest District Office: swdo24hournpdes@epa.state.oh.us
 Northwest District Office: nwdo24hournpdes@epa.state.oh.us
 Northeast District Office: nedo24hournpdes@epa.state.oh.us
 Central District Office: cdo24hournpdes@epa.state.oh.us
 Central Office: co24hournpdes@epa.state.oh.us

On a case-by-case basis it may be determined an environmental emergency exists. Report environmental emergencies within thirty (30) minutes of discovery to Ohio EPA 24-hours a day, 365 days a year at 800-282-9378!

Permittee Information	
Name of permittee:	Delaware County Board of Commissioners
NPDES Permit number:	4PK00003*ED
Contact name for permittee:	Mark Chandler
Contact telephone number:	1-740-296-7479
Date and time of discharge	
Date and time(s) of discharge:	December 8, 2017 8:45 Am Call came in
Date and time discharge discovered:	December 8, 2017 9:30 Am Delaware County Collections Crew on site
Description of discharge	
Approximate amount of discharge:	Estimated < 600 gallons
Characteristics of discharge:	Raw sewage from Cheshire air release manhole # 3
Stream(s) affected by discharge	
Provide the name of all streams affected by the discharge:	N/A none
Circumstances that created the discharge	
Describe the circumstances that created the discharge:	The air release was leaking in the top of it. Equipment failure
Contact person with knowledge of discharge (if different than above)	
Name:	Ricky Thomas
Telephone number:	1-740-972-1863
Remedial steps	
Describe all remedial steps which are or will be taken to address the discharge:	We cleaned up around the manhole and put a new air release on And washed down the road ditch as we was cleaning up.
Person responsible for implementing remedial steps	
Name:	Mark Chandler
Telephone number:	1-740-296-7479